

§ 119-58. Unlawful acts.

- (a) It shall be an unlawful act for any person to:
- (1) Sell any liquefied petroleum gas burning appliance designed or built for domestic use that has not been approved by the American Gas Association, Inc., the Underwriters Laboratory, Inc., or other laboratory approved by the Building Code Council.
 - (2) Repealed by Session Laws 1999-344, s. 1, effective July 22, 1999, and applicable to liquefied petroleum gas burning appliances installed on and after that date.
 - (3) Repealed by Session Laws 1999-344, s. 1, effective July 22, 1999, and applicable to liquefied petroleum gas burning appliances installed on and after that date.
 - (4) Fill a consumer tank or container in excess of 85 percent (85%) of its water capacity, or to fill a tank or container on the premises of a consumer that is not equipped with a fill tube or gauge; provided, the tank or container may be filled by weight if the tank or container is weighed before and after filling.
 - (5) Disconnect an appliance from a gas supply line without capping or plugging the line before leaving the premises.
 - (6) Turn on the gas after reestablishing an interrupted service without first having checked and closed all gas outlets.
 - (7) Violate any provisions of this Article or any rules adopted pursuant to this Article.

(b) Every supply tank or container with its regulating equipment connected in a service system, shall be identified while in service by the supplier with an attached tag, label, or other marking that includes the name of the person supplying liquefied petroleum gas to the system, and it shall be unlawful for any person, other than the supplier or the owner of the system, to disconnect, interrupt or fill the system with liquefied petroleum gas without the consent of the supplier. If another registered supplier is requested by the consumer to connect service and is given permission by the consumer to do so, the new supplier shall notify the former supplier before disconnecting the former service and connecting the new service and shall cap or plug all disconnected equipment outlets and leave the equipment in a condition consistent with this Article and the rules adopted pursuant to this Article. (1955, c. 487; 1959, c. 796, s. 3; 1961, c. 1072; 1981, c. 486, s. 1; 1987, c. 282, s. 17; 1999-344, s. 1.)